

Plant Master										
	Steam Used	Feedwater Used	Gas Used	Oil Used	Plant				Total	Outdoor
Time	Total	Total	Total	Total	Efficiency	Steam Cost	Gas Cost	Oil Cost	Fuel Cost	Temperature
00:00	21.64	22.62	24.58	0.0	85.4 %	9.09	196.65 \$	0.00 \$	196.65 \$	76 °F
01:00	21.72	21.83	24.56	0.0	85.8 %	9.05	196.51 \$	0.00 \$	196.51 \$	76 °F
02:00	21.49	20.93	25.34	0.0	82.3 %	9.43	202.70 \$	0.00 \$	202.70 \$	75 °F
03:00	22.22	22.77	25.14	0.0	85.7 %	9.05	201.11 \$	0.00 \$	201.11 \$	75 °F
04:00	23.37	24.45	26.44	0.0	85.7 %	9.05	211.53 \$	0.00 \$	211.53 \$	76 °F
05:00	23.72	23.29	26.75	0.0	86.0 %	9.02	213.98 \$	0.00 \$	213.98 \$	75 °F
06:00	24.14	23.48	27.19	0.0	86.1 %	9.01	217.50 \$	0.00 \$	217.50 \$	75 °F
07:00	24.52	25.58	28.23	0.0	84.3 %	9.21	225.81 \$	0.00 \$	225.81 \$	76 °F
08:00	24.79	25.88	29.04	0.0	82.8 %	9.37	232.31 \$	0.00 \$	232.31 \$	79 °F
09:00	24.88	25.02	28.06	0.0	86.0 %	9.02	224.45 \$	0.00 \$	224.45 \$	80 °F
10:00	24.51	23.99	27.55	0.0	86.3 %	8.99	220.42 \$	0.00 \$	220.42 \$	80 °F
11:00	24.18	24.59	27.29	0.0	86.0 %	9.03	218.29 \$	0.00 \$	218.29 \$	80 °F
12:00	24.11	25.26	27.39	0.0	85.4 %	9.09	219.15 \$	0.00 \$	219.15 \$	80 °F
13:00	24.04	24.27	28.46	0.0	81.9 %	9.47	227.68 \$	0.00 \$	227.68 \$	80 °F
14:00	24.07	24.04	27.26	0.0	85.7 %	9.06	218.05 \$	0.00 \$	218.05 \$	80 °F
15:00	23.69	24.06	26.74	0.0	85.9 %	9.03	213.91 \$	0.00 \$	213.91 \$	80 °F
16:00	23.99	24.38	27.18	0.0	85.6 %	9.06	217.46 \$	0.00 \$	217.46 \$	80 °F
17:00	24.48	24.74	27.78	0.0	85.5 %	9.08	222.22 \$	0.00 \$	222.22 \$	80 °F
18:00	24.84	25.26	29.41	0.0	81.9 %	9.47	235.27 \$	0.00 \$	235.27 \$	80 °F
19:00	25.63	25.84	29.17	0.0	85.2 %	9.11	233.37 \$	0.00 \$	233.37 \$	80 °F
20:00	24.55	24.43	27.65	0.0	86.1 %	9.01	221.19 \$	0.00 \$	221.19 \$	79 °F
21:00	25.50	25.73	29.00	0.0	85.3 %	9.10	231.98 \$	0.00 \$	231.98 \$	79 °F
22:00	25.67	25.69	29.04	0.0	85.7 %	9.05	232.33 \$	0.00 \$	232.33 \$	79 °F
23:00	26.21	25.87	29.63	0.0	85.8 %	9.04	237.02 \$	0.00 \$	237.02 \$	79 °F
	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Average</b>	<b>Average</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Avg</b>
	<b>577.97 klbs</b>	<b>584.01 klbs</b>	<b>658.86</b>	<b>0.0</b>	<b>85.1 %</b>	<b>9.12</b>	<b>5,270.90 \$</b>	<b>0.00 \$</b>	<b>5,270.90 \$</b>	<b>78 °F</b>

Feedwater System														
	Feedwater Header			Transfer Header			Deaerator Pressure	Boiler Feed Pump 1	Boiler Feed Pump 2	Boiler Feed Pump 3	Boiler Feed Pump 4	Transfer Pump 1	Transfer Pump 2	Transfer Pump 3
Time	Min	Max	Avg	Min	Max	Avg	Avg	Run-Time	Run-Time	Run-Time	Run-Time	Run-Time	Run-Time	Run-Time
00:00	185	193	189	47	50	49	3.7	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
01:00	186	195	191	47	51	49	3.7	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
02:00	189	195	192	48	51	50	3.8	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
03:00	185	194	189	46	51	49	3.7	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
04:00	182	189	186	47	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
05:00	183	193	188	47	50	49	3.7	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
06:00	184	192	188	33	54	48	3.7	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
07:00	181	188	184	42	50	47	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
08:00	181	188	184	46	49	47	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
09:00	181	189	185	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
10:00	184	191	187	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
11:00	183	190	186	45	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
12:00	181	189	185	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
13:00	184	190	187	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
14:00	184	192	187	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
15:00	182	191	187	47	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
16:00	182	191	187	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
17:00	183	189	186	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
18:00	180	190	185	46	49	48	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
19:00	180	188	184	45	49	47	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
20:00	181	191	186	46	49	48	3.6	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
21:00	181	188	184	46	48	47	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
22:00	179	188	184	46	49	47	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
23:00	180	189	184	46	49	47	3.5	0:00:00	0:00:00	1:00:00	1:00:00	0:00:00	1:00:00	0:00:00
	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Avg</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
	<b>179</b>	<b>195</b>	<b>187</b>	<b>33</b>	<b>54</b>	<b>48</b>	<b>3.6</b>	<b>0:00:00</b>	<b>0:00:00</b>	<b>24:00:00</b>	<b>24:00:00</b>	<b>0:00:00</b>	<b>24:00:00</b>	<b>0:00:00</b>

Boiler 1													
	Steam Pressure			Steam Used	Feedwater Used	Gas Used	Oil Used	Boiler		Average Steam		Total	
Time	Min	Max	Avg	Total	Total	Total	Total	Run-Time	I/O Efficiency	Cost \$/klbs	Gas Cost	Oil Cost	Fuel Cost
00:00	74	77	76	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
01:00	73	86	74	0.00	0.00	0.52	---	0:07:20	0.0 %	---	4.15 \$	---	4.15 \$
02:00	84	87	85	0.00	0.00	0.04	---	0:00:30	0.0 %	---	0.30 \$	---	0.30 \$
03:00	81	84	82	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
04:00	79	81	80	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
05:00	76	79	77	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
06:00	74	76	75	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
07:00	72	88	76	0.00	0.00	0.57	---	0:08:05	0.0 %	---	4.57 \$	---	4.57 \$
08:00	84	86	85	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
09:00	81	84	82	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
10:00	79	81	80	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
11:00	76	79	77	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
12:00	74	76	75	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
13:00	73	88	77	0.00	0.00	0.59	---	0:08:20	0.0 %	---	4.69 \$	---	4.69 \$
14:00	84	86	85	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
15:00	81	84	83	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
16:00	79	81	80	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
17:00	76	79	77	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
18:00	74	76	75	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
19:00	72	87	75	0.00	0.00	0.57	---	0:08:05	0.0 %	---	4.57 \$	---	4.57 \$
20:00	84	86	85	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
21:00	81	84	82	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
22:00	79	81	80	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
23:00	76	79	77	0.00	0.00	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Avg</b>	<b>Average</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
	72	88	79	0.00	0.00	2.29	---	0:32:20	0.0 %	---	18.28 \$	---	18.28 \$

Boiler 2													
	Steam Pressure			Steam Flow	Feedwater Flow	Gas Flow	Oil Flow	Boiler		Average Steam		Total	
Time	Min	Max	Avg	Total	Total	Total	Total	Run-Time	I/O Efficiency	Cost \$/klbs	Gas Cost	Oil Cost	Fuel Cost
00:00	75	78	76	0.00	0.38	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
01:00	72	75	74	0.00	0.38	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
02:00	71	87	78	0.00	0.38	0.59	---	0:07:50	0.0 %	---	4.74 \$	---	4.74 \$
03:00	82	85	84	0.00	0.39	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
04:00	79	82	81	0.00	0.39	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
05:00	76	79	78	0.00	0.39	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
06:00	74	76	75	0.00	0.39	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
07:00	71	75	72	0.00	0.40	0.16	---	0:02:05	0.0 %	---	1.29 \$	---	1.29 \$
08:00	75	87	84	0.00	0.42	0.42	---	0:05:40	0.0 %	---	3.37 \$	---	3.37 \$
09:00	80	83	82	0.00	0.42	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
10:00	77	80	79	0.00	0.41	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
11:00	75	77	76	0.00	0.41	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
12:00	72	75	73	0.00	0.41	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
13:00	71	87	81	0.00	0.41	0.58	---	0:07:45	0.0 %	---	4.65 \$	---	4.65 \$
14:00	81	84	82	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
15:00	78	81	79	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
16:00	75	78	77	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
17:00	73	75	74	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
18:00	71	87	77	0.00	0.40	0.58	---	0:07:45	0.0 %	---	4.62 \$	---	4.62 \$
19:00	82	85	83	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
20:00	79	82	80	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
21:00	76	79	78	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
22:00	74	76	75	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
23:00	71	74	72	0.00	0.40	0.00	---	0:00:00	---	---	0.00 \$	---	0.00 \$
	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Avg</b>	<b>Average</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
	71	87	78	0.00	9.56	2.33	---	0:31:05	0.0 %	---	18.67 \$	---	18.67 \$

Boiler 3													
	Steam Pressure			Steam Flow	Feedwater Flow	Gas Flow	Oil Flow	Boiler		Average Steam			Total
Time	Min	Max	Avg	Total	Total	Total	Total	Run-Time	I/O Efficiency	Cost \$/klbs	Gas Cost	Oil Cost	Fuel Cost
00:00	100	102	101	11.10	11.60	12.62	0.0	1:00:00	85.3 %	9.10	100.96 \$	0.00 \$	100.96 \$
01:00	100	102	101	11.13	11.00	12.58	0.0	1:00:00	85.8 %	9.04	100.65 \$	0.00 \$	100.65 \$
02:00	100	102	101	11.02	10.67	12.39	0.0	1:00:00	86.2 %	9.00	99.13 \$	0.00 \$	99.13 \$
03:00	100	102	101	11.37	11.68	12.88	0.0	1:00:00	85.6 %	9.06	103.05 \$	0.00 \$	103.05 \$
04:00	100	102	101	11.97	12.43	13.54	0.0	1:00:00	85.7 %	9.05	108.31 \$	0.00 \$	108.31 \$
05:00	100	102	101	12.12	11.85	13.67	0.0	1:00:00	86.0 %	9.03	109.38 \$	0.00 \$	109.38 \$
06:00	100	102	101	12.34	11.98	13.91	0.0	1:00:00	86.0 %	9.02	111.26 \$	0.00 \$	111.26 \$
07:00	100	102	101	12.54	12.96	14.27	0.0	1:00:00	85.3 %	9.10	114.17 \$	0.00 \$	114.17 \$
08:00	100	102	101	12.67	13.12	14.41	0.0	1:00:00	85.3 %	9.10	115.27 \$	0.00 \$	115.27 \$
09:00	100	102	101	12.66	13.06	14.33	0.0	1:00:00	85.7 %	9.06	114.67 \$	0.00 \$	114.67 \$
10:00	100	102	101	12.55	12.16	14.09	0.0	1:00:00	86.4 %	8.99	112.76 \$	0.00 \$	112.76 \$
11:00	100	102	101	12.41	12.12	13.94	0.0	1:00:00	86.3 %	8.99	111.56 \$	0.00 \$	111.56 \$
12:00	100	102	101	12.32	12.82	14.00	0.0	1:00:00	85.4 %	9.09	111.97 \$	0.00 \$	111.97 \$
13:00	100	102	101	12.24	12.73	13.97	0.0	1:00:00	85.0 %	9.13	111.73 \$	0.00 \$	111.73 \$
14:00	100	102	101	12.27	12.48	13.93	0.0	1:00:00	85.4 %	9.09	111.46 \$	0.00 \$	111.46 \$
15:00	100	102	101	12.18	11.84	13.68	0.0	1:00:00	86.4 %	8.98	109.45 \$	0.00 \$	109.45 \$
16:00	100	102	101	12.28	12.17	13.89	0.0	1:00:00	85.8 %	9.05	111.13 \$	0.00 \$	111.13 \$
17:00	100	102	101	12.47	12.94	14.21	0.0	1:00:00	85.1 %	9.11	113.70 \$	0.00 \$	113.70 \$
18:00	100	102	101	12.66	13.13	14.44	0.0	1:00:00	85.0 %	9.13	115.56 \$	0.00 \$	115.56 \$
19:00	100	102	101	13.14	12.71	14.89	0.0	1:00:00	85.6 %	9.07	119.16 \$	0.00 \$	119.16 \$
20:00	100	103	101	12.59	12.28	14.15	0.0	1:00:00	86.3 %	8.99	113.21 \$	0.00 \$	113.21 \$
21:00	100	102	101	13.00	13.50	14.84	0.0	1:00:00	85.0 %	9.13	118.68 \$	0.00 \$	118.68 \$
22:00	100	102	101	13.14	12.85	14.84	0.0	1:00:00	85.9 %	9.03	118.72 \$	0.00 \$	118.72 \$
23:00	100	102	101	13.40	13.03	15.13	0.0	1:00:00	85.9 %	9.04	121.07 \$	0.00 \$	121.07 \$
	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Avg</b>	<b>Average</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
	100	103	101	295.57	297.09	334.63	0.0	24:00:00	85.7 %	9.06	2,677.00 \$	0.00 \$	2,677.00 \$

Boiler 4													
	Steam Pressure			Steam Flow	Feedwater Flow	Gas Flow	Oil Flow	Boiler		Average Steam			Total
Time	Min	Max	Avg	Total	Total	Total	Total	Run-Time	I/O Efficiency	Cost \$/klbs	Gas Cost	Oil Cost	Fuel Cost
00:00	98	101	100	10.55	10.64	11.96	0.0	1:00:00	85.5 %	9.07	95.69 \$	0.00 \$	95.69 \$
01:00	98	101	100	10.59	10.45	11.98	0.0	1:00:00	85.7 %	9.05	95.85 \$	0.00 \$	95.85 \$
02:00	99	100	99	10.47	9.87	11.76	0.0	1:00:00	86.4 %	8.98	94.10 \$	0.00 \$	94.10 \$
03:00	98	101	100	10.85	10.70	12.26	0.0	1:00:00	85.9 %	9.04	98.06 \$	0.00 \$	98.06 \$
04:00	98	101	100	11.40	11.63	12.90	0.0	1:00:00	85.7 %	9.05	103.22 \$	0.00 \$	103.22 \$
05:00	98	101	100	11.60	11.05	13.08	0.0	1:00:00	86.1 %	9.01	104.60 \$	0.00 \$	104.60 \$
06:00	98	101	100	11.80	11.12	13.28	0.0	1:00:00	86.2 %	9.00	106.25 \$	0.00 \$	106.25 \$
07:00	98	101	100	11.98	12.22	13.63	0.0	1:00:00	85.2 %	9.11	109.06 \$	0.00 \$	109.06 \$
08:00	98	101	100	12.12	12.35	13.79	0.0	1:00:00	85.3 %	9.10	110.30 \$	0.00 \$	110.30 \$
09:00	99	101	100	12.22	11.55	13.72	0.0	1:00:00	86.4 %	8.98	109.79 \$	0.00 \$	109.79 \$
10:00	99	101	100	11.97	11.42	13.46	0.0	1:00:00	86.3 %	9.00	107.66 \$	0.00 \$	107.66 \$
11:00	98	101	100	11.77	12.07	13.34	0.0	1:00:00	85.6 %	9.07	106.74 \$	0.00 \$	106.74 \$
12:00	98	101	100	11.79	12.03	13.40	0.0	1:00:00	85.4 %	9.09	107.18 \$	0.00 \$	107.18 \$
13:00	99	101	100	11.80	11.13	13.33	0.0	1:00:00	85.9 %	9.04	106.65 \$	0.00 \$	106.65 \$
14:00	99	101	100	11.81	11.16	13.32	0.0	1:00:00	85.9 %	9.03	106.59 \$	0.00 \$	106.59 \$
15:00	98	101	100	11.51	11.82	13.06	0.0	1:00:00	85.5 %	9.08	104.46 \$	0.00 \$	104.46 \$
16:00	98	101	100	11.71	11.81	13.29	0.0	1:00:00	85.5 %	9.08	106.33 \$	0.00 \$	106.33 \$
17:00	99	101	100	12.00	11.40	13.56	0.0	1:00:00	85.8 %	9.04	108.52 \$	0.00 \$	108.52 \$
18:00	99	101	100	12.18	11.74	13.81	0.0	1:00:00	85.6 %	9.07	110.47 \$	0.00 \$	110.47 \$
19:00	99	101	100	12.48	12.73	14.28	0.0	1:00:00	84.8 %	9.15	114.21 \$	0.00 \$	114.21 \$
20:00	98	101	100	11.96	11.75	13.50	0.0	1:00:00	86.0 %	9.03	107.98 \$	0.00 \$	107.98 \$
21:00	99	101	100	12.50	11.83	14.16	0.0	1:00:00	85.6 %	9.06	113.30 \$	0.00 \$	113.30 \$
22:00	99	101	100	12.52	12.44	14.20	0.0	1:00:00	85.5 %	9.07	113.60 \$	0.00 \$	113.60 \$
23:00	99	101	100	12.81	12.44	14.49	0.0	1:00:00	85.7 %	9.05	115.95 \$	0.00 \$	115.95 \$
	<b>Min</b>	<b>Max</b>	<b>Avg</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>	<b>Avg</b>	<b>Average</b>	<b>Total</b>	<b>Total</b>	<b>Total</b>
	98	101	100	282.40	277.36	319.57	0.0	24:00:00	85.7 %	9.05	2,556.56 \$	0.00 \$	2,556.56 \$